

# **ESKOM**

---

## **APPLICATION FOR, SUSPENSION, ALTERNATE LIMITS AND POSTPONEMENT TIMELINES IN TERMS OF THE MINIMUM EMISSIONS STANDARDS FOR THE LETHABO POWER STATION**

**DATE: November 2018**

## TABLE OF CONTENTS

---

1	INTRODUCTION .....	4
2	ESKOM'S EMISSION REDUCTION PLAN OVERVIEW .....	4
3	REQUESTED POSTPONEMENT EMISSION LIMITS .....	6
4	LEGAL BASIS FOR DECISION-MAKING .....	7
4.1	Regulatory Requirements .....	7
4.2	Changes in Regulatory Framework .....	7
4.3	The Need to Amend the Variation Request .....	7
5	REASONS FOR APPLYING FOR POSTPONEMENT .....	8
5.1	Remaining Power Station Life .....	8
5.2	Water Availability .....	8
5.3	Environmental Implications of FGD .....	9
5.4	Impact on Ambient Air Quality .....	10
5.4.1	Sulphur Dioxide .....	10
5.4.2	Particulate Matter (PM <sub>10</sub> ) .....	10
5.4.3	Nitrogen Oxides (NO <sub>x</sub> ) .....	10
5.4.4	The Vaal Priority Area .....	11
5.4.5	Cumulative Assessment of Requested Emission Limits in the Northern Highveld .....	11
5.5	Cost implications of compliance with the MES .....	11
5.5.1	Direct Financial Costs .....	11
5.5.2	Electricity Tariff Implications .....	12
5.5.3	Cost Benefit Analysis .....	13
5.6	Project Delays .....	14
6	PUBLIC PARTICIPATION .....	15
7	EMISSION OFFSETS .....	15
8	CONCLUSIONS .....	17

## LIST OF FIGURES

---

Figure 1: Household Intervention for Lead Implementation Sites (KwaZamokuhle and Ezamokuhle).....16

## LIST OF TABLES

---

Table 1: Current and requested emission limits for Lethabo. ....7

## LIST OF ACRONYMS

AIR	Atmospheric Impact Report
AEL	Atmospheric Emission License
AQMP	Air Quality Management Plan
DEA	Department of Environmental Affairs
DOE	Department of Energy
EIA	Environmental Impact Assessment
ESP	Electrostatic Precipitator
FGC	Flue Gas Conditioning
FGD	Flue Gas Desulphurisation
GNR	Government Notice No.
HFPS	High Frequency Power Supply
FGD	Flue gas desulphurisation
IRP	Integrated Resource Plan
IRR	Issues and Response Report
LNB	Low NO <sub>x</sub> Burner
LPG	Liquid Petroleum Gas
NAAQS	National Ambient Air Quality Standards
NAQO	National Air Quality Officer
NEMAQA	National Environment Management: Air Quality Act, 2004 (Act No. 39 of 2004)
NEMA	National Environmental Management Act, 1998 (Act No. 107 of 1998)
NERSA	National Electricity Regulator of South Africa
NO	Nitrogen oxide
NO <sub>2</sub>	Nitrogen dioxide
NO <sub>x</sub>	Oxides of nitrogen (NO <sub>x</sub> = NO + NO <sub>2</sub> )
PM	Particulate Matter
PM <sub>10</sub>	Particulate Matter with a diameter of less than 10 µm
PM <sub>2.5</sub>	Particulate Matter with a diameter of less than 2.5 µm
RTS	Return to Service
SO <sub>2</sub>	Sulphur dioxide
TSP	Total Suspended Particulates
µm	1 µm = 10 <sup>-6</sup> m
WHO	World Health Organisation

## LIST OF ANNEXURES

---

Annexure A	Atmospheric Impact Report – Lethabo
Annexure B	Summary Atmospheric Impact Report
Annexure C	Health impact focussed cost benefit analysis
Annexure D	Public Participation report

## 1 INTRODUCTION

Eskom, as South Africa's public electricity utility, generates, transmits and distributes electricity throughout South Africa. The utility also supplies electricity to neighbouring countries including Namibia, Botswana, Zambia, Zimbabwe and Mozambique. Eskom's principal generation technology is pulverised coal with approximately 90% of its current generating capacity lying in coal-fired power stations. One of the 15 coal-fired power stations is the Lethabo Power Station (hereafter referred to as "Lethabo"), which lies in the Fezile Dabi District of the Free State Province.

In terms of the Integrated Resource Plan, stations will be decommissioned at 50 years. The exact date of decommissioning is determined by current and future demand, the performance of other electricity generating plants and the cost of generation. The last of Lethabo's generating units was commissioned in 1990 and it is intended to decommission the station between 2035 and 2040.

In terms of the National Environmental Management: Air Quality Act, 2004 (Act No. 39 of 2004) (NEMAQA), all of Eskom's coal and liquid fuel-fired power stations are required to meet the Minimum Emission Standards (MES) contained in GNR 1207 on 31 October 2018 ("GNR 1207") which was promulgated in terms of Section 21 of the NEMAQA<sup>1</sup>. GNR 1207 provides for transitional arrangements in respect of: a once off postponement with the compliance of minimum emissions for new plant for five years from the date of issue, no once off postponement will be valid beyond 31 March 2025; a once off suspension for plants being decommissioned by 31 March 2030; the National Air Quality Officer may grant an alternate emission limit or emission load if certain conditions are met. The application for any of these requests must be submitted by 31 March 2019.

Lethabo already achieves the 'existing plant' MES of 100 mg/Nm<sup>3</sup> for Particulate Matter (PM), 1100 mg/Nm<sup>3</sup> for Nitrogen oxides (NO<sub>x</sub>) and 3500 mg/Nm<sup>3</sup> for Sulphur dioxide (SO<sub>2</sub>) emissions. However, the Power Station will not be able to comply with the "new plant" MES of 50 mg/Nm<sup>3</sup> until the planned SO<sub>3</sub> plant upgrade and High Frequency Power Supply (HFPS) installation is completed by 2025 and as such a postponement of the new plant standard until 2025 is requested. The technology choice for Lethabo does however not guarantee compliance to the new plant limit and as such an alternate limit of 80 mg/Nm<sup>3</sup> until station decommissioning is requested. The station cannot comply with the new plant NO<sub>x</sub> limit of 750 mg/Nm<sup>3</sup> and an alternative limit of 1100 mg/Nm<sup>3</sup> is being requested. Similarly the station is unable to comply with the new plant limit of 1000 mg/Nm<sup>3</sup> for SO<sub>2</sub> and an alternate limit of 2600 mg/Nm<sup>3</sup> is being requested.

The purpose of this document is to present an application for postponement from specific MES compliance timeframes and propose alternative limits for Lethabo as required in terms of GNR 1207. The document has been structured to present an overview of Eskom's emission reduction plan including the current shut down of units for reserve storage, the decommissioning plan and its influence on Eskom's emissions. Based on this the proposed emission limits to which Lethabo could be held and which could then be included in the Atmospheric Emission Licence (AEL) are proposed. The legal basis for applying for postponement and alternative limits is then presented, including the requirements that must be met in making such an application. Finally, the reasons for the Application for suspension, postponement and/or alternative limits are presented.

## 2 ESKOM'S EMISSION REDUCTION PLAN OVERVIEW

Eskom considers that it is not practically feasible or beneficial for South Africa (when considering the full implications of compliance, planned decommissioning and health impacts) to comply fully with 'new plant' MES

by stipulated timeframes. As a result, Eskom proposes to adopt a phased and prioritised approach to compliance with the MES. The highest emitting stations will be retrofitted first. Reduction of Particulate Matter (PM) emissions has been prioritised, as PM is considered to be the ambient pollutant of greatest concern in South Africa. In addition, Eskom proposes to reduce NO<sub>x</sub> emissions at the three highest emitting stations. Kusile Power Station will be commissioned with abatement technology to achieve the new plant standards. Medupi is commissioned with abatement technology which can meet PM and NO<sub>x</sub> new plant standards and will be retrofitted with flue gas desulphurisation so that the new plant SO<sub>2</sub> limit will also be achieved at Medupi over time. There are six coal fired power stations which will be decommissioned before 2030, an additional two by 2035 and the remaining existing plants (excluding Majuba, Medupi and Kusile) by 2043.

Emission reduction interventions to achieve compliance with the new plant emission limits are planned for the following stations:

- Particulate Matter emission reduction: Tutuka, Kriel, Matla and Duvha Units 4-6, Matimba, Kendal and Lethabo;
- NO<sub>x</sub> emission reduction: at Matla, Majuba, Tutuka, Camden; and
- SO<sub>2</sub> emission reduction: at Medupi and pilot studies which will confirm the appropriate technology for Matimba and Kendal.

Currently the Integrated Resource Plan is based on a 50-year life for all power stations however the actual shut down and decommissioning dates of power stations are determined based on economic, supply and demand side criteria. In 2017/18 ten (10) units at Eskom's most costly and oldest plants namely Grootvlei, Hendrina and Komati were shut down for reserve storage. Based on the current electricity demand these three power stations will be shut down and later decommissioned before 2025. Further, Arnot, Camden, and Kriel will be decommissioned by 2030. The shutting down of these power plants will reduce the cumulative pollution in the three airsheds, some reduction has already materialised due to the 11 units which are shut down for reserve storage in 2017/18. The emissions load will continuously decrease ensuring that health impacts from Eskom's power stations will not increase.

The retrofits listed above are over and above the emission abatement technology which is already installed at Eskom's power stations, which is:

- Electrostatic Precipitators (ESPs) at Matimba, Kendal, Lethabo, Matla, Kriel, Tutuka, Komati and 3 of 6 units at Duvha. In addition SO<sub>3</sub> injection plants have also been installed at those stations with ESPs, except Tutuka, to improve the efficacy of the same;
- Fabric Filter Plants (FFPs) at Majuba, Arnot, Hendrina, Camden, Grootvlei, Medupi, Kusile, and 3 units at Duvha;
- Boilers with Low NO<sub>x</sub> burner design at Kendal and Matimba;
- Low NO<sub>x</sub> Burners (LNBS) at Medupi, Kusile, and on some units at Camden; and
- Flue gas desulphurisation (FGD) at Kusile.

Eskom applied and was granted postponements between 2014 and 2015. Since then Eskom has updated its emission reduction plan to include the enhancement of existing particulate matter abatement technology currently installed at Kendal, Matimba and Lethabo Power Stations.

Implementing the emission reduction plan and installing more efficient emission control technology will reduce Eskom's emissions. The decommissioning of the older stations and an increased use of the newer less emitting Medupi and Kusile power stations will also result in a substantial decrease in Eskom's emissions over time. For example, it is projected that compared to a 2020 baseline by 2035 Eskom's relative PM emissions will reduce by 58%, SO<sub>2</sub> by 66% and NO<sub>x</sub> by 46%.

Eskom's proposed atmospheric emission reduction plan is estimated to cost R 67 billion over the next 10 years. The cost have been included in the latest Multi Year Price Determination tariff application.

The retrofit schedule and projected emission reduction above clearly illustrates Eskom has been and remains committed to implementing emission reduction technologies to improve air quality in South Africa. Though there are delays in the implementation of the retrofit plan Eskom remains committed to ensuring these planned technology installations are completed.

A detailed discussion on Eskom's emission reduction plan is provided in the Eskom Summary Document.

### 3 REQUESTED POSTPONEMENT EMISSION LIMITS

Eskom's coal-fired Lethabo Power Station in the Free State Province has a total generation capacity of 3 708 MW.

The current limits listed in Table 1 are as in Lethabo's AEL (ref: FDDM-MET-2011-08-P1). The alternative emission limits that are requested for Lethabo during normal operating conditions are:

**Table 1: Current and Requested Emission Limits for Lethabo**

	Current Limit (from AEL)			Requested Emission Limits***		
	Limit value	Averaging period	Date to be achieved by	Limit value	Averaging period	Date to be achieved by
Particulate Matter	100	Monthly	1 April 2015	100	Daily	1 April 2020
	100	Daily	1 January 2016	80	Daily	1 April 2025
	50	Daily	1 April 2020			
Sulphur dioxide	3500	Daily	1 April 2015	3500	Daily Daily	1 April 2020
	2500		1 April 2020	2600		1 April 2025
Nitrogen oxides	1100	Daily	1 April 2015	1100	Daily Daily	1 April 2020
	1100		1 April 2020	1100		1 April 2025

*The requested interim emission limits above are in mg/Nm<sup>3</sup> at 273 K, 101.3 kPa, dry and 10% O<sub>2</sub>.*

In summary the postponement requested for Lethabo is: A postponement of the PM new plant MES until 2025 (when the planned retrofits are complete) with an alternative daily limit of 100 mg/Nm<sup>3</sup> until then and thereafter an alternate daily limit of 80 mg/Nm<sup>3</sup>. For SO<sub>2</sub> a postponement of the new plant standard is requested until 2025 with an alternative limit of 3500 mg/Nm<sup>3</sup> and thereafter an alternate daily limit of 2600 mg/Nm<sup>3</sup> is requested until decommissioning in 2040. For NO<sub>x</sub> postponement of the new plant standard until 2025 is requested and thereafter an alternative daily limit of 1100 mg/Nm<sup>3</sup> is requested until station decommissioning.

Based on the remaining life of the Lethabo power station, the techno-economics and cost benefit assessment any additional measures other than what was committed to above and the emission limits requested is not considered a socio-economic benefit and will not result in increased health impact.

It is requested that the proposed alternative emission limits only apply during normal working conditions, and not during start-up or shut-down, upset conditions and maintenance periods.

## **4 LEGAL BASIS FOR DECISION-MAKING**

### **4.1 Regulatory Requirements**

In terms of Section 14(1) of the NEMAQA, the Minister of Environmental Affairs ("Minister") must designate an officer in the Department of Environmental Affairs (DEA) as the National Air Quality Officer. In this regard, Dr Thuli Khumalo has been designated by the Minister as the current National Air Quality Officer. Section 14(4)(b) of the NEMAQA provides that the National Air Quality Officer may delegate a power or assign a duty to an official in the service of his/her administration. It is our understanding that no such delegation has been made for the area of jurisdiction in which the power station is located. Accordingly, Eskom submits this Application to the National Air Quality Officer (NAQO).

In terms of Paragraph (12)(a) – (c) of GNR 1207 of 31 October 2018 (the Regulations), the postponement application must include:

1. An air pollution impact assessment compiled in accordance with the regulations prescribing the format of an Atmospheric Impact Report (AIR) (as contemplated in Section 30 of the NEMAQA), by a person registered as a professional engineer or as a professional natural scientist in the appropriate category;
2. A detailed justification and reasons for the application; and
3. A concluded public participation process undertaken as specified in the National Environmental Management Act and the Environmental Impact Assessment (EIA) Regulations made under section 24(5) of the aforementioned Act.

In respect of these requirements we have attached –

1. As Annexure A, a copy of the AIR prepared in respect of Lethabo. The AIR provides, *inter alia*, an assessment of how ambient air quality is likely to be affected by Lethabo's requested emission limits by utilising, *inter alia*, atmospheric dispersion modelling;
2. Detailed justifications and reasons for the application (this document Section 5 below); and
3. A comprehensive report on the public participation process followed, and associated documentation (Annexure D).

### **4.2 Changes in Regulatory Framework**

In October 2018 the 2017 National Framework for Air Quality Management in the Republic of South Africa and the Amendment to Listed Activities and Associated Minimum Emission Standards Identified in terms of Section 21 of NEMAQA were published. While Eskom and the independent consultants appointed to complete the AIR will make every effort to provide complete information, Eskom reserves the right to supplement the information if it deems appropriate or if requested to do so by the NAQO.

### **4.3 The Need to Amend Variation Requests**

In terms of timing, Eskom is required to submit an AEL variation request parallel to the MES postponement application. The variation request is prepared based on the assumption that the requested MES postponement is granted by the NAQO. If the NAQO decision is substantially different from the requested postponement, Eskom reserves its right to amend its variation request.

## 5 REASONS FOR APPLYING FOR POSTPONEMENT

As mentioned above, the application for postponement must be accompanied by reasons. Such reasons are set out below and include the fact that emissions from Lethabo will not result in non-compliance with National Ambient Air Quality Standards (NAAQS), together with a suite of undesired environmental consequences of compliance with the MES including associated water demands, transport impacts and increases in waste and carbon dioxide (CO<sub>2</sub>) production. These undesired consequences together with the financial costs of compliance (such as an increase in the electricity tariff) must be weighed up against the benefits that will accrue as a result of compliance with the MES. It is Eskom's view that the benefit of compliance does not justify the non-financial and financial costs of compliance. (see section 5.5 below for the details of the cost-benefit analysis completed).

None of these reasons should be seen as exclusive (i.e. it is not one reason alone that indicates full compliance to the MES is not appropriate) but rather all in combination. As set out in the Constitution of the Republic of South Africa, there is the need to recognise the interrelationship between the environment and development. There is a need to protect the environment, while simultaneously recognising the need for social and economic development. There is the need therefore to maintain the balance in the attainment of sustainable development.

### 5.1 Remaining Power Station Life

Lethabo is currently scheduled to be decommissioned between 2035 and 2040, according to the Integrated Resource Plan which plans for a 50 year life for Eskom coal fired power stations.

Based on Eskom's experience at Medupi it is estimated that the time required for FGD development and construction would be 12 years (project development 4 years, commercial process 2 years and construction 6 years – one unit per year). Given these project timelines operation of FGD would only commence from 2032, 3 years before the station is to be decommissioning and 8 years before total decommissioning (assuming all other issues discussed below could be addressed). It is thus considered not financially viable to retrofit Lethabo with FGD given its current operating life.

### 5.2 Water Availability

Water is an extremely limited resource in South Africa and it is argued that the implementation of FGD at Lethabo is not an appropriate decision for a water scarce country.

Both wet and semi-dry FGD are critically dependant on large quantities of water being available at the power stations where FGD is deployed. Recent investigations undertaken for Medupi indicate that the implementation of FGD will increase its water requirement to up to 9 Mm<sup>3</sup>/annum. Wet FGD approximately triples the water consumption of a dry-cooled power station; semi-dry FGD more than doubles the water consumption of a dry-cooled power station (a wet cooled power station uses more than 10 times the amount of water of an equivalent dry-cooled power station. Typically 0.12 l/kWh for dry cooled to 2 l/kWh for wet cooled). The water demands of FGD increase the water required by a wet-cooled power station like Lethabo by some 20% (around 42 million m<sup>3</sup>/annum without FGD, to more than 51 million cubic metres per annum with wet FGD). The Lethabo Power Station being a wet-cooled power station already uses large quantities of water.



The water demands of FGD are thus significant across the power stations and will increase Eskom's water demand by some 58.7 million m<sup>3</sup>/annum – a 20% increase in the combined water consumption of Eskom's power stations<sup>2</sup>. This assumes the retrofit of all operating power stations.

The total water demands in the Integrated Vaal River Catchments presently exceed the water availability in the catchment until Phase 2A of the Lesotho Highlands Water Project (LHWP) is implemented. The projected completion date of Phase 2A of the LHWP now being beyond 2026. The water supply deficit is expected to grow with the growing urban demand in the greater Gauteng area. It is unlikely that DWS will license new major demands in this system until then. Thus far all efforts by DWS to reduce demand in the Vaal River system have been delayed or ineffective. Rand Water for example are requesting an increase in its water license volume to cater for the additional demand and DWS have refused thus far as there is no water available in the Vaal System.

Eskom has a combined water licence of 360 million m<sup>3</sup>/annum from the Vaal River Eastern Subsystem to generate electricity (licensed to October 2025 when it will get reviewed). Some of Eskom's older power stations are expected to be decommissioned within the next 5 to 10 years but that does not significantly contribute to reducing the shortages in the Vaal River System as the declining demand for Eskom's water use is already taken into account in the annual operating analysis. Eskom will not be able to re-allocate its water allocation to FGD as a relinquishing of our licenced volume goes back to DWS to determine whom would be the best user for the water being made available.

Beyond 2026 when LHWP 2 comes into operation it is possible that water is available for retrofits to the current fleet supplied from the Vaal System.

The argument is also not just one of having water available in the catchment, it is also one of determining whether FGD is a judicious use of what is an extremely scarce resource in South Africa in the face of multiple competing demands for that same resource. Especially since more than 98% of South Africa's available water has already been allocated.

### **5.3 Environmental Implications of FGD**

FGD is not without negative environmental consequences:

- Up to almost 261 000 tons of sorbent (limestone) per annum would be required to operate the FGD at Lethabo. The main source of sorbent is the Northern Cape, so the sorbent would need to be transported over hundreds of kilometres, preferably by rail or otherwise by road. The transport of the sorbent would result in environmental impacts, notably greenhouse gas emissions, and fugitive dust emissions. An increase in truck traffic would also result in an increase in driver mortalities, as has been observed in association with coal transport in Mpumalanga.
- Up to 547 000 tons of gypsum will be produced per annum as a by-product of the FGD process. If a high quality limestone is used, a high quality gypsum can be produced by wet FGD, and this could be taken up by the market for e.g. wallboard production. Lower grade gypsum can also be used for agricultural purposes. However, if there is not sufficient demand from the market, the gypsum will need to be disposed of in which case it would need to be managed carefully to ensure that there are no impacts on groundwater or air quality (from fugitive dust emissions).

---

<sup>2</sup> *\*Assuming that wet FGD is installed on the 5 newest stations excluding Kusile, and semi-dry FGD is installed on the rest of the coal-fired fleet, excluding stations which are decommissioned by 2030. The October amendment of the MES for SO<sub>2</sub> new plant to 1000 mg/Nm<sup>3</sup> will require a revision of technology choices. .*

- Lethabo is expected to produce an additional approximately 338 000 tons of CO<sub>2</sub> per annum, as the FGD process directly produces CO<sub>2</sub> as a by-product. In addition, the electricity output of Lethabo would be reduced by around 1% due to the additional auxiliary power requirements of the FGD, and correspondingly the relative CO<sub>2</sub> emissions would increase by 1%.

#### **5.4 Impact on Ambient Air Quality**

The DEA established an ambient air quality monitoring station at Three Rivers in Vereeniging, 9 km north-northeast of the Lethabo Power Station, measuring, amongst others, ambient SO<sub>2</sub>, NO<sub>2</sub> and PM<sub>10</sub> concentrations and meteorological parameters. The impact of Lethabo's emissions on ambient air quality has been comprehensively assessed in the accompanying independently compiled Atmospheric Impact Report (Annexure A). An analysis of ambient air quality data from the Sharpeville, Three Rivers, Sebokeng and Kliprivier ambient air quality monitoring stations indicates general compliance for the hourly, daily and annual average SO<sub>2</sub> NAAQS. Non-compliance is evident for the hourly NO<sub>2</sub> NAAQS for Sebokeng in 2015 and the annual average NO<sub>2</sub> NAAQS for Sharpeville and Sebokeng (also in 2015). For PM, non-compliance is evident across all the monitoring stations, for all the monitoring years for both PM<sub>10</sub> and PM<sub>2.5</sub> with a station like Sebokeng experiencing some 232 exceedances of the daily PM<sub>2.5</sub> limit value (where no more than 4 is allowed) implying a significant adverse health risk for the exposed population. Diurnal hourly averages exhibit pronounced morning and late afternoon peaks for PM<sub>10</sub>, PM<sub>2.5</sub> and NO<sub>2</sub>, with an approximate midday peak of SO<sub>2</sub> indicating the important contribution of ground level sources such as domestic fuel use to the peak values measured.

##### **5.4.1 Sulphur Dioxide**

Measured ambient SO<sub>2</sub> concentrations reveal full compliance with the NAAQS at the Three Rivers monitoring station. Dispersion modelling reveals predicted ambient SO<sub>2</sub> concentrations resulting from current and requested emission limits at Lethabo Power Station comply with the respective SO<sub>2</sub> NAAQS. The requested emissions limits are somewhat higher than current emissions, this is to allow for fluctuation of coal quality but the total load of emissions will be similar to the actual. The dispersion modelling results imply that emissions from Lethabo Power Station at current levels pose little risk of exceedance of the NAAQS for SO<sub>2</sub>.

##### **5.4.2 Particulate Matter (PM<sub>10</sub>)**

Ambient daily PM<sub>10</sub> concentrations measured at all the monitoring sites indicate high loading, and there is non-compliance with the daily and annual NAAQS for PM<sub>10</sub>. Analysis of diurnal data shows that the Lethabo Power Station does not contribute significantly to ambient PM<sub>10</sub> and that the exceedances derive from ground level emissions such as domestic fuel use. Dispersion model predictions of the impact of current actual emissions from Lethabo Power station and assuming that emissions from Lethabo are consistently at the limit value indicate that no exceedances of ambient limit values are predicted for PM<sub>10</sub> as a result of Lethabo's emissions. Current and future Particulate emissions from the power stations contribute only marginally to the measured ambient concentrations.

##### **5.4.3 Nitrogen Oxides (NO<sub>x</sub>)**

Measured ambient concentrations of NO<sub>2</sub> at the Three Rivers monitoring station are seen to be well below the NAAQS limits with full compliance with the standard. Non-compliance is evident for the hourly NO<sub>2</sub> NAAQS for Sebokeng in 2015 and the annual average NO<sub>2</sub> NAAQS for Sharpeville and Sebokeng (also in 2015). Dispersion modelling reveals predicted ambient NO<sub>2</sub> concentrations resulting from current and requested emissions at Lethabo Power Station easily comply with the respective NAAQS and so non-compliance with the NAAQS as a result of the requested emission appears to be highly unlikely.

#### **5.4.4 The Vaal Priority Area**

Eskom is aware that Lethabo is situated within the Vaal Priority Area and is, as such making a substantial financial investment into reducing emissions from Lethabo's operations, through the upgrading of the ESP and flue gas conditioning/SO<sub>3</sub> plant and the implementation of Eskom's full reduction plan as described in section 2 above. The complete installation of these technologies will bring the station well below the 'existing plant' standards for PM, while SO<sub>2</sub> and NO<sub>x</sub> remain within the 'existing plant' standards.

#### **5.4.5 Cumulative Assessment of Requested Emission Limits in the Northern Highveld**

In addition to the individual AIR completed for each power station, an air quality report, considering the cumulative impact of the Eskom stations over the impacted area of all of the present postponement applications was completed (Annexure B). The general conclusions of the analysis indicate that the quality of air will be in compliance with NO<sub>2</sub> National Air Quality Standards (NAAQS), but noncompliance with the daily and annual SO<sub>2</sub> standards in several areas across the Highveld. It is noteworthy that there are generally larger concentrations of SO<sub>2</sub> across the Highveld than seen to prevail in the Vaal Triangle but that NO<sub>2</sub> is generally higher in the Vaal than in the Highveld. Daily and annual average PM<sub>10</sub> and PM<sub>2.5</sub> concentrations could be in noncompliance and for extended periods of time. The effect of the above is that PM ambient levels currently result in increased health risk for a large part of the Highveld and Vaal.

Dispersion modelling results based on individual and combined power station emissions, excluding all other sources; indicate a negligible contribution to PM pollution. In addition the diurnal pattern in PM concentrations based on monitored ambient data clearly indicate a morning and early evening peaks, typical of low level source contributions. However, a combination of SO<sub>2</sub> and NO<sub>x</sub> emissions from all the Highveld power stations is predicted to form a significant component of the PM<sub>2.5</sub> load especially over Emalahleni area, which is in noncompliance with PM standards, is a cause for concern.

In addition, the combined SO<sub>2</sub> emissions from all Eskom power stations are predicted to contribute a significant amount to the pollution in and around the Emalahleni and Middelburg areas and even extending south towards Komati Power Station. However analysis indicates that the non-compliance is not only due to Eskom Power Stations but a function of a multitude of sources.

The dispersion modeling and ambient air quality monitoring data indicate that the elevated pollution levels in the Highveld and Vaal require a holistic approach, addressing all identified and potential sources. Therefore, a single approach, targeted at only eliminating Eskom power station emissions will not result in acceptable ambient air quality levels that are not harmful to human health and the environment.

### **5.5 Cost implications of compliance with the MES**

The financial implications of compliance to the MES, most especially the financial implications of compelling existing plants to comply with 'new plant' standards is presented below.

#### **5.5.1 Direct Financial Costs**

Eskom estimates that the CAPEX cost of full compliance with the MES at all Eskom's power stations is greater than R187 billion in 2018 real terms (excluding financing costs), and that annual OPEX costs are at least R5 billion per annum. This includes the costs for emission control for the entire existing fleet and flue gas desulphurisation at Medupi. Medupi's other emission abatement costs and all emission abatement costs for Kusile have been excluded from these totals because they have already been incorporated into the Medupi and Kusile projects. These costs are considered to be accurate to a factor of two.

The breakdown of the CAPEX costs is as follows:

- SO<sub>2</sub> emission reduction by FGD is estimated to cost R 140 – 175 billion. The estimated cost assumes R 15 - 26 billion per power station dependent on installed capacity and wet or dry FGD technology. It is taken that wet FGD is implemented on Medupi, Majuba, Matimba, Kendal, and Tutuka, (power stations being decommissioned after 2035) and that semi-dry FGD is implemented on Duvha, Lethabo and Matla (stations decommissioned between 2030 and 2035). For the tariff impact calculation an amount of R150 billion is used.
- NO<sub>x</sub> emission reduction by the most appropriate technology is estimated to cost between R10 and R40 billion for all power stations. This includes Low NO<sub>x</sub> Burner retrofits at stations which need them, and burner optimisations at others. For the tariff impact calculation an amount of R20 billion is used.
- Particulate Matter emission reduction by FFP retrofits is estimated to cost between R15 and R40 billion. For the tariff impact calculation an amount of R40 billion is used.

Full compliance with the MES at Lethabo would require a FGD retrofit, which is the only way of consistently achieving the new plant SO<sub>2</sub> emission limit, an cost of between R 15 – 20 billion and a LNB retrofit estimated to be around R2 billion, as well as FFP retrofit and dust handling plant upgrade (CAPEX of over R5 billion).

The CAPEX cost estimates were derived as follows:

- FGD: Costs for existing stations are based on a study done by EON Engineering for all Eskom's power stations in 2006, adding on provisions for balance of plant considerations and owner's development costs, and inflated to 2018 costs. Costs are considered to be accurate to a factor of 2. Costs for Medupi are according to the Concept Design Report, and are considered to be accurate to within 20%.
- Low NO<sub>x</sub> Burners and/or Overfired Air: Costs are based on International Energy Agency (2006) costs, escalated for inflation, rate of exchange and Owner Development Costs. Costs are considered to be accurate to a factor of 2.
- FFPs: Costs are based on actual tender prices for an enquiry for FFP retrofits at Matla and Duvha in 2011/12. Costs are considered to be accurate to 40% for Tutuka, Matla and Duvha and to approximately a factor of 2 for other power stations.

The OPEX costs are only for flue gas desulphurisation, and are also based on costs in the EON Engineering report for the existing fleet, and on costs in the Medupi Concept Report for Medupi. Again, the OPEX costs do not include OPEX for Kusile. The main cost items are the sorbent (limestone), water, gypsum disposal, auxiliary power and maintenance costs. For the tariff impact calculation an amount of R6.3bn per annum is used.

The certainty with which Eskom presents costs depends on the stage of the project. Before concept release approval, costs are based on averages of published international data and benchmarks for similar technologies, and so are considered to be accurate to a factor of two. Once the conceptual designs have been done, costs are generally accurate to within 50%. Once the detailed designs are completed, costs are considered to be accurate to within 20%. Once the contracts have been placed, costs are considered to be accurate to within 10%. There is only complete certainty about the costs once the contract has been completed.

### **5.5.2 Electricity Tariff Implications**

The electricity tariff is the mechanism through which the cost of producing electricity is recovered from the consumers thereof. The cost of compliance with the MES would be part of the inherent cost of production of electricity in future. Eskom has estimated that full compliance with the MES by 2020 would require the electricity tariff to be on average between 7 and 10% higher than what it would be in the absence of the emission abatement retrofits, over a 20-year period. The different between the base tariff and the tariff including the costs of MES compliance would be slightly higher (than the mentioned average) in the earlier years and slightly lower than the mentioned average in the later years. The implications for the tariff are of course

dependent on when the emission abatement retrofits are installed, and what assumptions are used for interest and inflation rates and future base electricity tariffs.

This tariff calculation is based on the following assumptions:

- The CAPEX and OPEX costs are the mid-point amounts as provided above.
- The CAPEX costs are incurred in 2020, and fully implemented over a period of up to six years (with a shorter period resulting in the higher %, in the range mentioned above).
- The average remaining power station life is 20 years, thus the CAPEX costs for the retrofits are depreciated over a 20-year period.
- The inflation rate is 6%.
- Nominal pre-tax cost of capital is 14%.
- Cost-reflective electricity tariffs are reached within five years after Multi Year Price Determination 3.

The electricity tariff is applied for by Eskom, but decided on by the National Electricity Regulator of South Africa (NERSA). Eskom has included the CAPEX required to cover the proposed emission reduction plan with an estimated cost of R 67 billion over the next 10 years, it is covered in the MYPD4 application (for costs over the next 5 years). If there is a requirement for additional retrofits based on the DEA response to this application, these costs would need to be provided for through the tariff, failing which Eskom's financial health will further deteriorate and the ability to raise funding for these projects would be limited. The original assumptions are still at risk. If the price increase of 15% per annum is not approved by NERSA, Eskom would need to further prioritise its operations and seek further support to its balance sheet. In addition, Eskom has not reached a level where it is recovering its efficient and prudent costs (even at the end of the MYPD 4 period if the 15% increase is approved).

### **5.5.3 Cost Benefit Analysis**

The basis of the assessments of the impact of Lethabo's emissions on human health and the environment is a comparison of the measured and predicted air quality concentrations with the NAAQS. Stakeholders have argued correctly that the NAAQS cannot be interpreted to imply no health risk at all but the counter argument is that the NAAQS express a 'permissible' level of risk. To manage air quality to a point that it is completely free of risk is to invoke such significant financial and non-financial costs that those costs will in themselves result in severe potential economic and social consequences. In these terms it is necessary to present here some perspectives on the cost-benefit of full MES compliance.

The 2017 National Air Quality Framework for Air Quality Management provision is made for suspensions and alternative emission limits due to the potential economic implications of emission standards on existing plant. The provision is provided because a sector specific CBA was not completed prior to setting standards. Eskom commissioned a CBA to support the decision making process for this application (Annexure C).

The aim of the CBA study was to determine the health costs associated with current emissions, health benefits associated with compliance to the new Minimum Emission Standards, and the direct and indirect costs of compliance. The baseline scenario to determine the cost to health assumed no new abatement technologies would be installed, resulting in relative emissions being constant for each power plant.

The model estimated the increased exposure as a result of Eskom's emissions from the 13 power stations in 2018 would result in an additional 320 cases of premature mortality (assuming no new abatement technology implemented). To translate these health outcomes (cases of mortality) to a health cost, a Value of a Statistical Life of R53 million was attributed to each mortality, resulting in a R17.6 billion baseline health cost in 2018.

The outcomes of the analysis is that scenario 2, Eskom's proposed reduction plan and scenario 4, Eskom's proposed reduction plan plus decommissioning of Komati, Grootvlei and Hendrina had the best cost to benefit ratios with costs 1.8 and 1.3 times higher than the benefits. The full compliance option which would have most power stations retrofitted had the worst cost benefit ratio of costs 5.3 times higher than the benefits. The Eskom reduction plan with the addition of Kendal and Matimba FGD reflected costs 2.2 times higher than benefits.

Given the significance of low level emissions even if Lethabo complies with the new plant PM MES, the reduction in PM emissions will make no material difference to the health risks posed by ambient PM<sub>10</sub> concentrations. Implementation of the PM reduction technology will however inflate the cost of electricity, making it more unaffordable to poor communities who are typically exposed to elevated PM<sub>10</sub> concentrations thereby curtailing access to one of the most potentially effective means of mitigating the current health risk. In cost-benefit terms the financial cost will result in no real benefit, and the financial cost will bring about potentially material negative social consequences in further hindering access to electricity.

In respect of SO<sub>2</sub> emissions the cost-benefit is more difficult to qualify. Although the risk of non-compliance with the NAAQS is generally low, stakeholders have presented that it is 'unacceptable to allow the continued emissions of large quantities of SO<sub>2</sub>'. In principle this comment is accepted but again the argument is one of weighing up both the financial and non-financial costs of reducing those emissions. The argument has already been made that the water use implications of SO<sub>2</sub> control are untenable and that the cost benefit ratio does not support FGD as the best option to reduce the impact on health.

No argument is presented anywhere in these applications that reducing atmospheric emissions is not required. The argument is simply one of ensuring that emissions reductions are carefully planned and phased so that the associated cost-benefit is positive. A key consideration is that half of the existing Eskom power stations will be shut down and decommissioned in the next 10 – 15 years significantly reducing the emissions. The planned offset project which will reduce low level emissions in communities in the vicinity of Eskom power station has not been studied long enough to conclusively provide cost benefit. However initial assessment indicates a significant reduction in exposure to indoor air pollution

## **5.6 Project Delays**

Emission retrofit of the type being planned require years of planning, which precede a lengthy installation process, as well as substantial capital funding and power station down-time. The planning process involves Eskom internal processes that allow for technology concept and -design approval after which significant funds need to be allocated to the project. Being a state owned entity, government approval for projects of such a nature is also required which lead to the additional project development time-lines. Contracts to commence the project are only put in place once carefully regulated commercial processes have been completed.

Over and above the aforementioned milestones, the actual commencement of the installation of the abatement technology at a unit needs to be carefully scheduled to fit into a six-month unit outage time, which is usually planned alternatingly for each unit (i.e. one unit per year) as part of an official longer term outage schedule. Once a unit is taken down for maintenance, it is not operational, and thus does not contribute power to the grid. Unit down-time needs to take into account fleet generation capacity and can only take place, if Eskom is sure the country's energy demands can be met. Once the pollutant specific abatement technology has been installed, it takes months for the relevant technology to function optimally (optimisation period), as test-runs and assessments take place to ensure the equipment functions to its design capacity (in this case for NO<sub>x</sub> and PM to meet 'new plant' emission standards). The optimisation period for FFPs is typically 9 months and the optimisation period for LNBS can typically take up to a year, emphasising that abatement technology installation

completion does not automatically signify immediate full compliance but an immediate reduction in emissions is realised.

The process to implement projects such as the emission retrofit projects is complex and there is a continual risk of delays affecting planned project completion dates. Notwithstanding implementing controls to reduce project delays such as high level project oversight and attempts to ensure the commercial processes are completed within reasonable timelines some of the retrofit projects have been subject to delays.

The emission projects planned for Lethabo have already been subject to some two years of delay. This delay is attributable largely to commercial process issues. Tenders were advertised for the Lethabo upgrades twice but the bids received did not meet the local production and content requirements. In terms of procurement rules National Treasury approval must now be sought to cancel the enquiry and a 6 months 'cooling off' period is required before the tenders can be re-issued to the market.

## **6 PUBLIC PARTICIPATION**

The requirement that the public participation process for an application for postponement from the MES follow the process specified in the NEMA Environmental Impact Assessment (EIA) Regulations. Eskom supports and aligns its public participation process with the requirements as stipulated within the NEMA EIA Regulations. The public participation process followed for this postponement application has increased the number of public meetings to include communities in the vicinity of the power stations, in the case of Lethabo meetings were held in Vereeniging and Sharpsville. With regards to the AEL variation request to be submitted, the public participation process undertaken meets the requirements of Section 46 of NEMAQA. For details pertaining to the public participation process, the reader is referred to Annexure D of this Application.

## **7 EMISSION OFFSETS**


Eskom is willing to implement emission offsets in areas where power stations impact significantly on ambient air quality, and where there is non-compliance with ambient air quality standards as a condition of a granted postponement. Eskom is of the view that in many cases household emission offsets are a more effective way of reducing human exposure to harmful levels of air pollution, than is retrofitting power stations with emission abatement technology. Emission retrofits at power stations also increase the cost of electricity, which may make electricity unaffordable for more people, resulting in an increase in the domestic use of fuels and deterioration in air quality in low income areas.

Eskom has undertaken several feasibility and pilot studies (2011 – 2018) in KwaZamokuhle, a township near Hendrina Power Station to identify and test potential offset interventions. Based on the results of the studies conducted to date, it was concluded that ambient air quality in the affected communities could be improved by replacing household's coal stoves with a hybrid gas electricity stoves and a LPG heater together with retrofitting the houses with a ceiling to insulate the houses.

The recommended Air Quality Offset intervention for the lead implementation (in KwaZamokuhle and Ezamokuhle) entails the following (Figure 5);

- Provision of a basic plus retrofit which consists of;
  - o Insulation entailing installation of a SPF ceiling system and draft proofing
  - o Electrical rewiring and issuance of Certificate of Competence (CoC).
- Stove swap which entails

- Provision of electricity based energy source with LPG backup. This will include a hybrid electric gas stove, LPG heater plus 2x9 kg LPG cylinders and Compact fluorescent lamp (CFL) for energy efficiency lighting.
- Removal and disposal of the coal stove



**Figure 1: Household Intervention for Lead Implementation Sites (KwaZamokuhle and Ezamokuhle)**

The lead implementation in KwaZamokuhle and Ezamokuhle is planned to commence earlier in 2019. The large scale rollout of offset intervention is planned for 2019 to 2025 (including offset interventions for Kriel Power Station).

In the Vaal region waste burning is seen as a major contributor to ambient air pollution and offset solutions to address this are being planned. The poor state of the local municipality is however contributing to delays in the delivery of interventions in the area.



## 8 CONCLUSIONS

Eskom is committed to ensuring that it manages and operates its coal-fired power stations in such a manner that risks to the environment and human health are minimised and socio-economic benefits are maximised. As set out in the Constitution of the Republic of South Africa, there is the need to recognise the interrelationship between the environment and development. There is a need to protect the environment, while simultaneously recognising the need for social and economic development. There is the need therefore to maintain the balance in the attainment of sustainable development.

The Eskom Emission Reduction Plan will lead to a reduction in total emissions from several power stations specifically particulate emissions. Further six power stations will be decommissioned by 2030 reducing the total load of all emissions in each of the three air sheds applicable to this year's application.

An analysis of ambient air quality data from the Sharpeville, Three Rivers, Sebokeng and Kliprivier ambient air quality monitoring stations indicates general compliance, the instances of non-compliance the modelled impact of Lethabo indicates that diurnal hourly averages exhibit pronounced morning and late afternoon peaks for  $PM_{10}$ ,  $PM_{2.5}$  and  $NO_2$ , with an approximate midday peak of  $SO_2$  indicating the important contribution of ground level sources such as domestic fuel use to the peak values measured. Lethabo on  $SO_2$  shows that it does not individually create a situation of non-compliance. Considering this, the costs and the implications of implementing FGD it is not considered appropriate to implement FGD and an alternative limit of  $2600 \text{ mg/Nm}^3$  is proposed.

The financial costs of compliance with the MES will translate into an increase in the electricity tariff.

The long lead time of 12 years required to design, procure and construct a flue gas desulphurisation plant and Eskom's financial position which limits funding options, it is requested that this is considered in the decision making process.

The Air Quality offset programme initiated by Eskom will continue to be implemented, based on current information Eskom believes this programme will reduce direct exposure to harmful indoor pollution and improve the quality of life.

Eskom believes given the motivation presented above in terms of its complete emission reduction plan and its implications and the specific detail in respect of Lethabo that the application for the requested alternate limits are appropriate and in line with the relevant regulatory and policy requirements and as such the application should be approved by the NAQA.

Given that a revised National Framework for Air Quality Management and the Amendment of Listed Activities and Emission Standards were only published in October 2018 and there is a requirement to submit applications by 31 March 2019, Eskom will comply with this but reserves the right to submit additional information including additional modelling scenarios which assess the closure of power stations, a high level assessment of technologies which could meet the new  $1000 \text{ mg/Nm}^3$   $SO_2$  emission limit and any other aspects of significance.